

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 1582

PRINT OR TYPE ONLY

1. OWNER Bently-Buckeye Ranch ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS OWNER DONALD BENTLY
Minidoka, Nev.

2. LOCATION NW 1/4 SW 1/4 Sec. 24 T 13 @ S R. 20 E Douglas County
 PERMIT NO. 43388 Buckeye Ranch Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY & Cobble stones		0	53	
CLAY SAND		53	100	
GRAVEL	X	100	103	
CLAY w/STREAKS of fine SAND		103	226	
SAND & GRAVEL w/ some CLAY	X	226	275	

8. WELL CONSTRUCTION
 Diameter hole 8 5/8 inches Total depth 275 feet
 Casing record 275'
 Weight per foot _____ Thickness 188

Diameter	From	To
<u>12</u> inches	<u>0</u> feet	<u>50</u> feet
<u>8 5/8</u> inches	<u>50</u> feet	<u>275</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type CEMENT
 Depth of seal 52 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation Factory slot
 Size perforation 3x3/32
 From 230 feet to 270 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 36' feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

Date started 3-5-84 19____
 Date completed 3-20-84 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3450</u>	<u>30</u>	<u>126</u>	<u>7</u>
_____	_____	_____	_____
_____	_____	_____	_____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name KAWCHACK DRILLING INC. Contractor
 Address Box 536 Gardnerville, Nev. Contractor
 Nevada contractor's license number 021268
 Nevada contractor's drillers number 1380
 Nevada driller's license number 763 Actual Driller
 Signed Eddy J Kawchack Contractor
 Date 3-21-84

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. 20 Draw down 14 feet 4 hours
 G.P.M. _____ Draw down _____ feet _____ hours