

PRINT OR TYPE ONLY

In Book

WELL DRILLERS REPORT

Please complete this form in its entirety



NOTICE OF INTENT NO. 1431

OWNER Bill Pipes
 MAILING ADDRESS 1532 Owyhee
Las Vegas, Nev. 89110

ADDRESS AT WELL LOCATION Corner of Ann Rd.
& El Capitan

2. LOCATION SW 1/4 SE 1/4 Sec 29 T. 19 N. R. 60 E Clark County

PERMIT NO. 46381 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Quasi-Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & gravel		0	20	20
Sand, grav. some cement.		20	40	20
Sand & gravel		40	50	10
Gravel w/ clay streaks		50	90	40
Gravel w/ limestone		90	110	20
Hard limestone		110	115	5
Hard clay w/gravel		115	250	135
Gravel		250	365	115
Cemented gravel		365	400	35

8. WELL CONSTRUCTION

Diameter hole 12 1/4 inches Total depth 400 feet
 Casing record _____
 Weight per foot _____ Thickness .188
 Diameter From To
* 8 inches +1 feet 400 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 400 feet

Perforations:
 Type perforation Punched
 Size perforation 3/16x2 4 rows 4" centers
 From 280 feet to 400 feet
 From _____ feet to _____ feet

RECEIVED
 MAR 12 1984
 Div. of Water Resources
 Branch Office - Las Vegas, Nev.

9. WATER LEVEL

Static water level 230 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name THOMPSON DRILLING CO., INC.
4185 West Harmon
 Address Las Vegas, Nevada 89103
 Contractor
 Nevada contractor's license number 4286A
 Nevada contractor's drillers number 582
 Nevada driller's license number 1377 (J.W. Thompson)
 Actual Driller
 Signed Richard T. Thompson
 Contractor
 Date March 12, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours