

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 4339

PRINT OR TYPE ONLY

1. OWNER RICHARD KAZDA
 MAILING ADDRESS (Ken Butler) Contractor
 ADDRESS AT WELL LOCATION 2620 Pleasant View Place
 2. LOCATION NW ¼ NW ¼ Sec 01 T 19 N/S R. 20E E Washoe County
 PERMIT NO. 30-204-11 Parcel No. ✓ Subdivision Name Sunset View Rancho Estates

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Dark Brown Clay		0	12	12
Brown Clay with White sand		12	28	16
Tan Clay and Ash		28	45	17
Red Volcanic Rock		45	96	51
Hard Volcanic Rock Loose and very coarse		96	135	39
Reds and Black Rock with gray layers		135	191	56
Clay layer (gray)		191	193	2
Conglomerate of colors of greasy rock		193	217	24
Red Volcanic Rock		217	220	3
Black Volcanic Rock with streaks of Red	X	270	286	16
T.D. 286				

8. 10" - 58 ft WELL CONSTRUCTION
 Diameter hole 6 5/8 inches Total depth 286 feet
 Casing record 6 5/8 - .156
 Weight per foot 10.78 Thickness .156
 Diameter 5" inches From 106 feet To 123 feet
+18" From 106 feet To 286 feet
 Surface seal: Yes No Type grout
 Depth of seal 52 feet
 Gravel packed: Yes No
 Gravel packed from 52 feet to 123 feet
 Perforations:
 Type perforation factory
 Size perforation 3/32
 From 101 feet to 123 feet
 From 266 feet to 286 feet

9. WATER LEVEL
 Static water level 246 feet below land surface
 Flow 19 G.P.M. P.S.I.
 Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling and Well Service Contractor
 Address 2255 Glendale Sparks, Nv. 89431 Contractor
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1132 Actual Driller
 Signed PM Thal Contractor
 Date 4/20/84

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blew well with 250# of air at 600 C.F.M. to clean and develop</u>			

BAILER TEST
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours