

OFFICE USE ONLY  
 Log No. 25299  
 Permit No. DOMESTIC  
 Basin PERSON V. 8-105  
 NOTICE OF INTENT NO. 2657

**WELL DRILLERS REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Carl Kidman ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS PO. 320 Genoa Nevada  
 2. LOCATION SE 1/4 NW 1/4 Sec 23 T 13 N/S R 19 E Douglas County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

| Material                 | Water Strata | From | To  | Thick-ness |
|--------------------------|--------------|------|-----|------------|
| Sandy loam topsoil       |              | 0    | 15  | 15         |
| Blue Gumbo Clay          |              | 15   | 25  | 10         |
| Fine Black Sand          | X            | 25   | 30  | 5          |
| Coarse Sand #            | X            |      |     |            |
| Gravel                   |              | 30   | 62  | 32         |
| Fine Sand w Clay Streaks |              | 62   | 70  | 8          |
| Fine Sand                | X            | 70   | 125 | 55         |
| Coarse Sand              | X            | 125  | 148 | 23         |

Date started 4-17 1984  
 Date completed 4-20 1984

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
|          |        |           |                  |
|          |        |           |                  |
|          |        |           |                  |

BAILER TEST  
 G.P.M. 20+ Draw down 0 feet 1 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

8. WELL CONSTRUCTION  
 Diameter hole 8 inches Total depth 148 feet  
 Casing record 0-148  
 Weight per foot \_\_\_\_\_ Thickness 1.88  

| Diameter         | From           | To              |
|------------------|----------------|-----------------|
| <u>12</u> inches | <u>0</u> feet  | <u>50</u> feet  |
| <u>8</u> inches  | <u>50</u> feet | <u>148</u> feet |
| _____ inches     | _____ feet     | _____ feet      |
| _____ inches     | _____ feet     | _____ feet      |
| _____ inches     | _____ feet     | _____ feet      |
| _____ inches     | _____ feet     | _____ feet      |

 Surface seal: Yes  No  Type Cement  
 Depth of seal 0-50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation Saw Slot  
 Size perforation 3/32 X 2 1/2  
 From 131 feet to 145 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 3 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold F. Quality Good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Edmund Miller Contractor  
 Address Box 92 Smith, NV Contractor  
 Nevada contractor's license number 12272  
 Nevada contractor's drillers number 718  
 Nevada driller's license number 718  
 Signed Edmund Miller Actual Driller  
 Date 4-21-84