

OFFICE USE ONLY  
 Log No. 25304  
 Permit No. DOMESTIC  
 Basin WSPR.V. 6-84  
 NOTICE OF INTENT NO. 4538

**WELL DRILLERS REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Harold Thomas ADDRESS AT WELL LOCATION Gray Van Road  
 MAILING ADDRESS Stees  
 2. LOCATION NE NE  $\frac{1}{4}$  Sec. 1 T. 22 N/S R. 20 E. Washoe County  
 PERMIT NO. 76-241-09 Parcel No. Palomino Valley Subdivision Name June 1-2-84  
 Issued by Water Resources

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other  air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soft brown Clay & D.G.		0	24	24
Granodirite		24	117	93
Green granite very hard		117	130	13
Green D.G.		130	158	28
Hard Granodirite	X	158	185	
T.D. 185				

8. 10" for 56' WELL CONSTRUCTION  
 Diameter hole 8" inches Total depth 185 feet  
 Casing record 6 5/8" for 185'  
 Weight per foot 10.78 Thickness .156  
 Diameter From To  
6 5/8 inches 18" feet 185 feet  
 Surface seal: Yes  No  Type grout  
 Depth of seal 51' feet  
 Gravel packed: Yes  No   
 Gravel packed from 51 feet to 185 feet  
 Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 163 feet to 185 feet

9. WATER LEVEL  
 Static water level 100' feet below land surface  
 Flow 30+ G.P.M. P.S.I.  
 Water temperature cool ° F. Quality good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling and Well Service Contractor  
 Address 2255 Glendale Sparks, Nv 89431 Contractor  
 Nevada contractor's license number 15291  
 Nevada contractor's drillers number 1132  
 Nevada driller's license number 1132 Actual Driller  
 Signed Roger M. Thrall Contractor  
 Date 4/27/84

Date started 4/23, 1984  
 Date completed 4/24, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blew well with air to clean and develop</u>			

BAILER TEST  
 G.P.M. Draw down feet hours  
 G.P.M. Draw down feet hours  
 G.P.M. Draw down feet hours