

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 4340

PRINT OR TYPE ONLY

1. OWNER KEN BUTLER ADDRESS AT WELL LOCATION 5004 Pleasant View Drive
 MAILING ADDRESS 3310 Martini Sparks, nv

2. LOCATION SW $\frac{1}{4}$ NE $\frac{1}{4}$ Sec X 01 T 19 N/S R. 20 E WASHOE County
 PERMIT NO. 30-201-1 - SUNSET VIEW RANCH ESTIMES
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ROCKS AND COBBLES LOOSE		0	95	95
RED VOLCANIC ROCK		95	205	110
SMALL TRACE OF RED CLAY		205	206	1
HARD GRAY CLAY ROCK	X	206	225	19
RED VOLCANIC ROCK WITH GRAY GRAVELS	X	225	245	20
T.D. 245				

8. 10" for 50W WELL CONSTRUCTION
 Diameter hole 8" inches Total depth 226 feet
 Casing record 6 5/8
 Weight per foot 10.78 Thickness .156
 Diameter 6 5/8" inches From 18+ feet To 226 feet
 inches feet feet feet
 Surface seal: Yes No Type Grout
 Depth of seal 51' feet
 Gravel packed: Yes No
 Gravel packed from 51' feet to 226 feet

Perforations:
 Type perforation FACTORY
 Size perforation 3/32 x 3"
 From 209 feet to 226 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 160 feet below land surface
 Flow 30+ G.P.M. _____ P.S.I.
 Water temperature COOL ° F. Quality GOOD

Date started 4/27 1984
 Date completed 4/28 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
DEVELOPED WITH AIR- one hour			

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AQUA DRILLING AND WELL SERVICE INC.
2255 GLENDALE AVE Contractor
 Address SPARKS, NV Contractor
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1379 Actual Driller
 Signed Roger M. Thrall Contractor
 Date 5/1/84

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours