

OFFICE USE ONLY
 Log No. 25323
 Permit No. DOMESTIC
 Basin CARSON V. B-105

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 4263

1. OWNER Doug Trono ADDRESS AT WELL LOCATION 1375 Saratoga
 MAILING ADDRESS Gardnerville, Nev

2. LOCATION $\frac{1}{4}$ $\frac{1}{4}$ Sec. 28 T. 14 N/S R. 20 E Douglas County
 PERMIT NO. _____ Parcel No. _____ Subdivision Name Johnston home

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SAND & CLAY</u>		<u>0</u>	<u>24</u>	
<u>FINE SAND</u>		<u>24</u>	<u>35</u>	
<u>SAND & CLAY</u>		<u>35</u>	<u>62</u>	
<u>CLAY</u>		<u>62</u>	<u>85</u>	
<u>SAND</u>		<u>85</u>	<u>106</u>	

8. WELL CONSTRUCTION
 Diameter hole 6 5/8 inches Total depth 106 feet
 Casing record 106
 Weight per foot _____ Thickness 56

Diameter	From	To
<u>10</u> inches	<u>0</u> feet	<u>54</u> feet
<u>6 5/8</u> inches	<u>54</u> feet	<u>106</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type GROUT
 Depth of seal 54 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation FACILITY 5.0"
 Size perforation 3X1/16
 From 86 feet to 106 feet
 From _____ feet to _____ feet

Date started 4-7-84, 19____
 Date completed 4-7-84, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 22 feet below land surface
 Flow _____ G.P.M. 20 P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Kaufbach Drilling Inc. Contractor
 Address Box 536 Gardnerville, Nev Contractor
 Nevada contractor's license number 021268
 Nevada contractor's drillers number 545
 Nevada driller's license number 763
 Signed Steve Kaufbach Actual Driller
 Date 4-10-84 Contractor

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours