WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 25326
Permit No. 46461/49186
Basin 10-153

PAGE #-1-

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Robert E. Burnham ADDRESS Dv Rte Box 33 Eureka Nv, 89316

2. LOCATION SW ¼ NW ¼ Sec. 29 T. 23 N/X R. 54 E. MDBM Eureka County
PERMIT NO. 46461

3. TYPE OF WORK: New Well [X] Recondition [ ] Deepen [ ] Other [ ]

4. PROPOSED USE: Domestic [X] Irrigation [X] Test [ ] Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL: Cable [ ] Rotary [X] Other [ ] Reverse

6. LITHOLOGIC LOG

S+G = Sand + Gravel

Material	Water Strata	From	To	Thickness
Top Soil		0	2	
S+G		2	13	
Black Mud		13	47	
Black + Brown Clay		47	155	
Clay + BLK Sand		155	157	
Clay		157	158	
BLK Sand		158	159	
Clay		159	166	
BLK S+G		166	169	
Clay		169	172	
BLK S+G		172	175	
Clay		175	183	
BLK Sand		183	188	
Clay		188	225	
BLK Sand		225	230	
Clay + BLK Sand		230	246	
Clay pebbles		246	248	
Clay		248	358	
S+G		358	359	
Clay		359	360	
S+G		360	363	
Clay		363	366	
S+G some Clay		366	370	
Clay		370	393	
hard brown sandstone		393	396	
Brown chippy sandstone		396	398	
S+G		398	399	

CONT ON PG 2

Date started 5-4, 1984
Date completed 5-7, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter hole 28 inches Total depth 449 feet
Casing record
Weight per foot ..... Thickness .250

Diameter	From	To
16 inches	0 feet	291 feet
12 inches	291 feet	436 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type Cement
Depth of seal 50 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 449 feet

Perforations:
Type perforation Roscoe Moss Full FLO
Size perforation + STD. FLO
From Full 153 feet to 177 feet
From STD 177 feet to 201 feet
From Full 201 feet to 249 feet
From Full 339 feet to 436 feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 10 Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Plaskett Irr. Co.
Address P.O. Box 10 Eureka NV
Nevada contractor's license number 11882
Nevada driller's license number 706
Signed Walter Plaskett
Date 5-9-84

USE ADDITIONAL SHEETS IF NECESSARY

O-627

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No.
Permit No.
Basin

PAGE # -2-

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Robert E. Burnham ADDRESS

2. LOCATION SW ¼ NW ¼ Sec. 30 T. 23 N/S R. 54 E County
PERMIT NO. 46461

3. TYPE OF WORK SEE PG 1 4. PROPOSED USE 5. TYPE WELL

New Well ☐ Recondition ☐ Domestic ☐ Irrigation ☐ Test ☐ Cable ☐ Rotary ☐
Deepen ☐ Other ☐ Municipal ☐ Industrial ☐ Stock ☐ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
cont From Page -1-				
clay		399	402	
Sst &		402	404	
clay		404	407	
Sand Stone		407	409	
Brown Sand + Sst &		409	412	
clay		412	416	
Clay + Sst &		416	421	
Sst &		421	427	
clay		427	430	
Cemented gravel		430	432	
clay + Sst & stringers		432	441	
Fine sand		441	447	
cemented gravel		447	449	
NOTE:				
28" MCAB DRAG BIT + 10' of 8"				
Drill pipe lost in bottom				

Date started, 19
Date completed, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION

Diameter hole inches Total depth feet
Casing record
Weight per foot Thickness

Diameter	From	To
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

SEE

Surface seal: Yes ☐ No ☐ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Plaskett Inc. Co.
Address PO Box 10 Eureka NV 89316
Nevada contractor's license number 11882
Nevada driller's license number 706
Signed Walter Plaskett
Date 5-4-84

USE ADDITIONAL SHEETS IF NECESSARY

O-627