WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 25354
Permit No. DOMESTIC
Basin CARSON V. 8-105

Card # 2793

1. OWNER ED ROZNOWSKI ADDRESS Gardnerville NV 89410
4 @ 20 Eagle Mt East end T/2 E.

2. LOCATION ¼ ¼ Sec. 10 T. 10 N/S R. 22 E. Douglas County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLAY + SAND		0	10'	
BROWN CLAY + SAND + ROCK		10'	30'	
BROWN CLAY + ROCK		30'	140'	
GRAY CLAY + GRAVEL		140'	145'	
GRANITE (SOLID)		145'	220'	
BROKEN GRANITE	XX	220'	240'	

Date started 4-17, 1984
Date completed 5-15, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 10 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10" — 8" inches Total depth 50 — 240 feet
Casing record +1 — 240
Weight per foot Thickness .188

Diameter	From	To
8 inches	0 feet	190 feet
4 inches	180 feet	240 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation FACTORY
Size perforation 3 X 3/32
From 220 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 190 Feet below land surface
Flow G.P.M.
Water temperature COLD °F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name KAWCHACK DRILLING, INC.
P. O. Box 536
Gardnerville, NV. 89410
Address 267-2138
Nevada contractor's license number 021268
Nevada driller's license number 545
Signed Steve Kawchack
Date 5-15-84

USE ADDITIONAL SHEETS IF NECESSARY

O-627