

Log No. 25358  
 Permit No. DOMESTIC  
 Basin PLEASANT V. 6-87

*ASB*

**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 4533  
15924 Caswell

PRINT OR TYPE ONLY

1. OWNER Keith Hamilton/High Sierra Const/ ADDRESS AT WELL LOCATION  
 MAILING ADDRESS 1665 Lakeside  
Reno, Nv 89509

2. LOCATION NW 1/4 NE 1/4 Sec. 34 T. 17 N/S R. 19 E. Washoe County  
 PERMIT NO. 47-040-08  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Loose top soil</u>				
<u>Bolders &amp; cobbles</u>		<u>0</u>	<u>62</u>	<u>62</u>
<u>Hard Granite Gray</u>		<u>62</u>	<u>77</u>	<u>15</u>
<u>Layers of Gravel</u>				
<u>Sand and Granite</u>		<u>77</u>	<u>102</u>	<u>25</u>
<u>Gravel Mixed</u>				
<u>with Cobbles</u>		<u>102</u>	<u>145</u>	<u>43</u>
<u>Sand Gravels</u>		<u>145</u>	<u>165</u>	<u>20</u>
<u>T.D 165</u>				

8. 10" for 60' WELL CONSTRUCTION  
 Diameter hole 8 inches Total depth 157 feet  
 Casing record 6 5/8  
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+18</u> feet	<u>157</u> feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet

Surface seal: Yes  No  Type grout  
 Depth of seal 52' feet  
 Gravel packed: Yes  No   
 Gravel packed from 52 feet to 157 feet

Perforations:  
 Type perforation Factory - slot  
 Size perforation 3/32 X 3  
 From 137 feet to 157 feet  
 From ..... feet to ..... feet

9. WATER LEVEL  
 Static water level 65 feet below land surface  
 Flow 25 G.P.M. 150 P.S.I.  
 Water temperature cool ° F. Quality Good

Date started 5-16, 1984  
 Date completed 5-17, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blew well with air to clean and develop</u>			

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling and Well Service Inc.  
 Contractor  
 Address 2255 Glendale Ave Sparks, Nevada  
 Contractor  
15291  
 Nevada contractor's license number  
1132  
 Nevada contractor's drillers number  
1379  
 Nevada driller's license number  
 Actual Driller  
 Signed Roger M. Thrall  
 Roger M. Thrall Contractor  
 Date May 19, 1984

BAILER TEST

G.P.M. .... Draw down ..... feet ..... hours  
 G.P.M. .... Draw down ..... feet ..... hours  
 G.P.M. .... Draw down ..... feet ..... hours