WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 25360
Permit No. DOMESTIC
Basin TR. MEADOWS 6-87

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER William Pennington
MAILING ADDRESS 2600 Greensboro Dr. Reno Nev. 89509
ADDRESS AT WELL LOCATION Circus, Circus Reno

2. LOCATION ¼ ¼ Sec. 27 T. 19 N/S R. 19 E Washoe County
PERMIT NO. Issued by Water Resources | 26ccbb Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand gravel & Rocks		0	163	163
Lightly Fractured Rock Volcanic		163	305	142
Large fractures Volcanic Rock		305	311	6
Multi colored grey, green, Blue, Brown		311	487	176
fractured Volcanic Rock		487	543	56
hard green Volcanic Rock		543	629	76
Grey clay		629	809	180
multi colored Volcanic Rock lenses in clay		809	880	71
Very hard Volc. Rock		880	1026	
Large fracture	X	1026	1027	1
Volc. Rock w/ unstable Zones	X X	1027	1120	98
Red cinder Material		1120	1138	18
soft Volcanic Rock (unstable)		1138	1229	91

Date started 3-5, 1984
Date completed 4-3, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10" & 8" inches Total depth 1229 feet
Casing record
Weight per foot 8⅝" 21-6" 11 Thickness 8⅝ .188 To 6⅝ .188

Diameter	From	To
inches	feet	feet
8⅝ O.D. inches	0 feet	1026 feet
inches	feet	feet
6⅝ O.D. inches	1020 feet	1229 feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Pumped grout
Depth of seal 1026 feet
Gravel packed: Yes ☐ No ☑
Gravel packed from — feet to — feet

Perforations:
Type perforation factory sawed
Size perforation 3/32 x 2½ D.R. 8⅝ 6⅝ 3/32 x 2½"
From feet to feet
From 1011-8⅝ feet to 1026 feet
From feet to feet
From 1020-6⅝ feet to 1211 feet
From feet to feet

9. WATER LEVEL
Static water level 325 feet below land surface
Flow approx. 100 G.P.M. — P.S.I.
Water temperature 177 °F. Quality unkone

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best ~~of my~~ knowledge.
Name Paul Williams & Sons
Contractor
Address 22 So. Patterson, Sparks Nev.
Contractor
Nevada contractor's license number 14483
Nevada contractor's drillers number 957
Nevada ~~driller's~~ license number 957
Actual Driller
Signed Paul E Williams
Contractor
Date 4-3-84

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434