

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 2942 *BC*

1. OWNER W.T. Thompson ADDRESS AT WELL LOCATION 1229 Melbourne Way
 MAILING ADDRESS 1229 Melbourne Way Minden Nev.
 2. LOCATION SW 1/4 SW 1/4 Sec 28 T 14 N/S R. 20 E Douglas County
 PERMIT NO. 21085-12 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy Clay</u>	<u>—</u>	<u>0</u>	<u>12</u>	<u>12</u>
<u>sand</u>	<u>—</u>	<u>12</u>	<u>38</u>	
<u>sandy clay</u>	<u>—</u>	<u>38</u>	<u>52</u>	
<u>coarse sand</u>	<u>—</u>	<u>52</u>	<u>81</u>	
<u>Iron clay</u>	<u>—</u>	<u>89</u>	<u>92</u>	<u>3</u>

8. WELL CONSTRUCTION
 Diameter hole 8 inches Total depth 92 feet
 Casing record +1-92
 Weight per foot _____ Thickness 1.28

Diameter	From	To
<u>1 1/2</u> inches	<u>0</u> feet	<u>52</u> feet
<u>8</u> inches	<u>52</u> feet	<u>92</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Conc. grout
 Depth of seal 52 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Factory Milled
 Size perforation 1/16
 From 70 feet to 90 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 12 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature 64.5° F. Quality good

Date started June 16, 1982
 Date completed July 2, 1982

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Jim House & Son's Contractor
 Address 106 N. Rainbow Dayton Nev. Contractor
 Nevada contractor's license number 12554
 Nevada contractor's drillers number —
 Nevada driller's license number 580 Actual Driller
 Signed Jim House Contractor
 Date July 5, 1982

BAILER TEST
 G.P.M. 2.0 Draw down 4.5 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours