WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 25394
Permit No. Domestic
Basin: Big Smokey V. 10-137(B)

NOTICE OF INTENT NO. 3282

1. OWNER Harold & Alice Davis
MAILING ADDRESS P.O. Box 315
Beatty, Nevada 89003

ADDRESS AT WELL LOCATION Round Mt., Nevada

2. LOCATION S E ¼ S E ¼ Sec. 32 T. 11N N/S R. 43 E Nye County
PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [X] Rotary [ ]
Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil brown		0	3	3
Clay brown		3	15	12
Gravel brown		15	17	2
Gravely-clay brown		17	50	33
Gravel brown	w.b.	50	59	9
Gravely-clay brown		59	75	16
Gravel brown	W. B.	75	94	19
Sandy-clay brown		94	125	31
Gravel brown	w.b.	125	132	7
Gravely-clay brown		132	147	15
Sand & gravel brown	W.B.	147	155	8

Date started May 22, 1984
Date completed May 24, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 30 Draw down 25 feet 1 hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 150 feet
Casing record 150 ft. six inch casing
Weight per foot 11 Thickness .156

Diameter	From	To
6 inches	0 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type cement
Depth of seal 50 feet
Gravel packed: Yes [ ] No [X]
Gravel packed from ____ feet to ____ feet

Perforations:
Type perforation Torch
Size perforation 5 by 1/8 inch
From 110 feet to 150 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level + 1 feet below land surface
Flow 7 G.P.M. 2 P.S.I.
Water temperature 54 ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T & R WELL DRILLING (Contractor)
Address 9015 S. Grassvalley Rd. Winnemucca, Nv. (Contractor)
Nevada contractor's license number 017721
Nevada contractor's drillers number 1190
Nevada driller's license number 1190 (Actual Driller)
Signed Thomas D. Stribs (Contractor)
Date May 25, 1984

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434