WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 75397
Permit No. Domestic
Basin BIG SMOKEY V. 10-137(B)

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3278

1. OWNER Terry E. DeWolfe
MAILING ADDRESS 1142 Kenton Drive
Montery Park, Calif. 91754

ADDRESS AT WELL LOCATION Round Mt. Nevada

2. LOCATION NW ¼ NW ¼ Sec. 9 T. 10N N/S R. 43 E Nye County
PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [X] Rotary [ ]
Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Soil		0	1	1
Gravel brown		1	3	2
Gravel-w-strips of clay brown		3	37	34
Gravely-clay brown		37	60	23
Gravel & sand brown	WB	60	71	11
Sandy-clay-w-strips of gravel brown		71	83	12
Sandy-clay brown		83	112	29
Clay-w-strips of sand and gravel brown	WB	112	151	39

Date started April 25, 19 84
Date completed April 27, 19 84

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 40 Draw down 15 feet 1 hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 150 feet
Casing record 150 ft. of six-inch casing
Weight per foot 1.1 Thickness 156

Diameter	From	To
6 inches	0 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type cement
Depth of seal 50 feet
Gravel packed: Yes [ ] No [X]
Gravel packed from ____ feet to ____ feet

Perforations:
Type perforation Torch
Size perforation 5inch by 1/8 inch
From 110 feet to 150 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 26 feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature 54 ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name T & R WELL DRILLING (Contractor)
Address 9015 S. Grassvalley Rd. Winnemucca (Contractor)
Nevada contractor's license number xx 017721
Nevada contractor's drillers number 1190
Nevada driller's license number 1190 (Actual Driller)
Signed Thomas D. Stubs (Contractor)
Date May 17, 1984

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434