WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

Int. 1529

STATE OF NEVADA
DIVISION OF WATER RESOURCES

Permit + Well

OFFICE USE ONLY
Log No. 25410
Permit No.
Basin WASHOE 1/2 6-89

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Sandy Wise ADDRESS #1 Ranch Rd. Carson City

2. LOCATION NE ¼ NE ¼ Sec. 27 T. 16 N/S R. 19 E County
PERMIT NO. 36323

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☑ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
D.G. + Rock		0	70	70
Granite Fractured with Clay		70	190	120
Fractures Some Water		190	220	30
Granite + Fractures		220	320	100

Date started 5/24, 19 84
Date completed 5/30, 19 84

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blown	47-50	30	3 Hr.

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12" inches Total depth 320 feet
Casing record 8 5/8
Weight per foot 13.87 Thickness .188

Diameter	From	To
8 5/8 inches	0 feet	220 feet
6 5/8 inches	220 feet	320 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60' feet to 220 feet

Perforations:
Type perforation Factory
Size perforation 3/32 x 3
From 180 feet to 220 feet
From feet to feet
From 280 feet to 320 feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 70 Feet below land surface
Flow 0 G.P.M. 47-50
Water temperature Cold °F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sierra Pump + Drilling
Address Carson City
Nevada contractor's license number 012236
Nevada driller's license number 1001
Signed Cletus Bludsworth by Buck Stracener
Date 6/4/84

USE ADDITIONAL SHEETS IF NECESSARY

O-627