WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 25423
Permit No. DOMESTIC
Basin WASHOE V. 6-89

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4644

1. OWNER Tom Di Loreto
MAILING ADDRESS 90 W. Grove Suite 500
Reno, Nv 89509

ADDRESS AT WELL LOCATION 7150 Franktown Road

2. LOCATION SW NE ¼ SW ¼ Sec. 22 T. 16 N/S R. 19 E Washoe County
PERMIT NO. 59015-6-7 (Issued by Water Resources) | 55-200-55 (Parcel No.) | Old Washoe City (Subdivision Name)

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [ ] Irrigation [X] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ] mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand and clay		0	42	42
granodirite fractured		42	191	149
granodirite solid		191	243	52
T.D. 243				
UTM E 0254891				
NAD27 N 4346335				
RC 8-4-06				

Date started 5-23, 1984
Date completed 5-25, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
air lift to clean and develop			
test pumped @ 160 ft - 47 GPM			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 243 feet
Casing record
Weight per foot ..... Thickness .188

Diameter	From	To
8 5/8 inches	18" feet	243 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type Slurry
Depth of seal 52 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 52 feet to 243 feet

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 203 feet to 243 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 22' feet below land surface
Flow 35 by air lift G.P.M. ..... P.S.I.
Water temperature cool °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling and Well Service, Inc (Contractor)
Address 2255 Glendale Sparks, Nv 89431 (Contractor)
Nevada contractor's license number 15291
Nevada contractor's drillers number 1132
Nevada driller's license number 1379
Signed Roger M. Thrall (Actual Driller) (Contractor)
Roger M. Thrall
Date 5/31/84

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434