WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 25481
Permit No. DOMESTIC
Basin TR. MEADOWS 06-87

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1885

1. OWNER George Schindler
MAILING ADDRESS 4055 Warren Way
Reno, Nv. 89509

ADDRESS AT WELL LOCATION
4055 Warren Way Reno, Nev.

2. LOCATION NW ¼ ¼ Sec. 25 T. 19 N/S R. 19 E. Washoe County
PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE (Geothermal)
Domestic [ ] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ]

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand<&Rock | | 0 | 35 | 35 |
| Sand W S Clay & Rock | | 35 | 55 | 20 |
| Sand W S Clay & Rock | | 55 | 80 | 25 |
| Clay W S Sand | | 80 | 115 | 35 |
| Sand W S Clay | | 115 | 155 | 40 |
| Clay & Sand | | 155 | 215 | 60 |
| Sand & Clay | | 215 | 235 | 20 |

Date started 8-8, 1983
Date completed 8-13, 1983

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| 3600 | 30 | 40 | 10 |

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 235 feet
Casing record
Weight per foot Thickness 156

| Diameter | From | To |
|---|---|---|
| 4½ inches | 0 feet | 235 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes [X] No [ ] Type cement
Depth of seal 80 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 195 feet to 235 feet

Perforations:
Type perforation 1/8 slot
Size perforation
From 200 feet to 235 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 30 feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature 132 °F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Larry Brinkerhoff (Contractor)
Address 2270 Eastlake Blvd Carson City (Contractor)
Nevada contractor's license number 20578
Nevada contractor's drillers number 1168
Nevada driller's license number 730 (Actual Driller)
Signed ____ (Contractor)
Date 9-10-83

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434