WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

Int 1525

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 25486
Permit No. 46411
Basin CARSON V. 08-105

I

1. OWNER Murray G Alstott ADDRESS PO Box 7
2290 Main St. Genoa Nev. Genoa Nev.

2. LOCATION NE ¼ SW ¼ Sec. 9 T. 13 N/S R. 19 E. Douglas County
PERMIT NO. 46411

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☑ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Rock + Bolders		0	100	100
Brown Clay with Streaks of Sand + Gravel		100	161	61.

Date started 6/28, 1984
Date completed 6/30, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blown	100	0	3 Hr.

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12" inches Total depth 161 feet
Casing record 8 5/8
Weight per foot 12.89 Thickness 188

Diameter	From	To
8 5/8 inches	0 feet	161 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50' pumped feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 161 feet

Perforations:
Type perforation Factory
Size perforation 3/32 x 3
From 80 feet to 161 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 45 Feet below land surface
Flow 0 G.P.M. 100
Water temperature Cold ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sierra Pump + Drilling
Address Carson City Nev.
Nevada contractor's license number 0122360
Nevada driller's license number 1001
Signed Cirtus Bludsworth by Buck Stracener
Date 7/5/84

USE ADDITIONAL SHEETS IF NECESSARY

O-627