

**I**

**WELL DRILLERS REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

SOUTH TRUCKEE

NOTICE OF INTENT NO. 3678 ✓

1. OWNER MEADOWS GENERAL IMPROVEMENT DISTRICT ADDRESS AT WELL LOCATION  
 MAILING ADDRESS DEPT OF PUBLIC WORKS 1 mile west of Lolezzi Lane & Highway 395  
1205 MILL STREET RENO, NV 89520 then 3/4 mile south

2. LOCATION 1/4 NE 1/4 Sec. 19 T. 18 NYS R. 20 E WASHOE County  
 PERMIT NO. WAIVER - 136  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE #6  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
silt, sand, & boulders		0	130	130
hard drlg, silts, sand & boulders		130	160	30
silt to boulders		160	190	30
silty sand & gravel		190	220	30
mixed sand, gravel & boulders		220	280	60
silt to med sand		280	300	20
fine sand to fine gravel		300	325	25
fine silt to coarse sand		325	335	10
silt to fine gravel		335	370	35
silty sand		370	375	5
silt to fine gravel, minor clay - intermittent		375	470	95
clayey, silty sand		470	490	20
decreasing clay, coarse sand		490	500	10
silty sand to med gravel		500	545	45
dirty silty sand		545	580	35
clay, silt, sand, gravel		580	600	20
clay, silt & sand		600	650	50
clayish sand		650	660	10
blue to purple clay		660	680	20

8. WELL CONSTRUCTION

Diameter hole 8 inches Total depth 680 feet  
 Casing record TEST WELL NOT CASIED  
 Weight per foot..... Thickness.....  

Diameter	From	To
.....inches	.....feet	.....feet

 Surface seal: Yes  No  Type.....  
 Depth of seal abandonment feet  
 Gravel packed: Yes  No   
 Gravel packed from.....feet to.....feet  
 Reamed to well under permit 48028 W-143  
 Perforations:  
 Type perforation.....  
 Size perforation.....  
 From.....feet to.....feet  
 From.....feet to.....feet  
 From.....feet to.....feet  
 From.....feet to.....feet  
 From.....feet to.....feet

Date started JUNE 7, 19 84  
 Date completed JUNE 10, 19 84

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. .... Draw down.....feet .....hours  
 G.P.M. .... Draw down.....feet .....hours  
 G.P.M. .... Draw down.....feet .....hours

9. WATER LEVEL

Static water level.....feet below land surface  
 Flow bottom G.P.M. .... P.S.I.  
 Water temperature 67 °F. Quality.....

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CHARLES SARGENT IRRIGATION, INC.  
 Contractor

Address P. O. BOX 2480 RENO, NV 89505  
 Contractor

Nevada contractor's license number 21246

Nevada contractor's drillers number 1391 LARRY WHITESEL

Nevada driller's license number 1388 GENE MAPEL

Signed Gene Mapel Actual Driller  
 Contractor

Date JUNE 16, 1984