WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 25521
Permit No. Domestic
Basin WALKER LAKE 09-110(B)

I

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4287

1. OWNER John H. Jacobs
MAILING ADDRESS 2621 Santa Rosa Ave.
Altadena, CA 91001

ADDRESS AT WELL LOCATION

2. LOCATION ¼ ¼ Sec. 9 T. 9 N/S R. 29 E Mineral County
PERMIT NO. Domestic (Issued by Water Resources) B. (Parcel No.) Jensen Parcel Map FILE # 36885 NOV 9, 1978 (Subdivision Name)

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Uncolidated G.		0	15	
Cemented G.		15	40	
Gravel		40	43	
Gravel & clays		43	48	
Boulders, G. clay		48	60	
Gravel & clay		60	74	
Gravel & sand		74	87	
Broken rock boulders		87	105	
Gravel & ~~sand~~ clays		105	117	
Broken hard rock		117	122	
Gravel & sand		122	128	
Braken hard limestone		128	139	
Gravel tan clay		139	146	
Solid hard volcanics		146	158	
Broken volcanics		158	165	
Rounded gravel sands		165	180	
Broken Quartz		180	185	
Quartz and pyrites		185	210	

Date started 7-5-84, 1984
Date completed 7-9, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blowed App. 75 G.P.M.			
for several hours			
recovered good			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 9 7/8 inches Total depth 190 feet
Casing record 6 5/8" O.D.
Weight per foot ..... Thickness .188

Diameter	From	To
6 inches	0 feet	190 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type cement
Depth of seal 50' feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50' feet to 190' feet

Perforations:
Type perforation slot cut
Size perforation 1/8"
From 145' feet to 190' feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 79 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature x ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Potter Drilling Co. (Contractor)
Address P.O. Box 1815, Fallon, NV (Contractor)
Nevada contractor's license number 020161
Nevada contractor's drillers number 1348
Nevada driller's license number 1378 (Actual Driller)
Signed [signature] (Contractor)
Date July 10, 1984

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434