WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 25522
Permit No. DOMESTIC
Basin LEMMON V. 92(B)

(I)

NOTICE OF INTENT NO. 3713

1. OWNER: CHARLES COLTRIN
MAILING ADDRESS: 2615 Tybo Ave, Reno, NV 89512
ADDRESS AT WELL LOCATION: 11645 Juniper, Reno, NV 89506

2. LOCATION: NW ¼ NE ¼ Sec. 15 T. 21N N/S R. 19 E Washoe County
PERMIT NO. (Issued by Water Resources): 080-414-06 (Parcel No.) Lemmon Valley (Subdivision Name)

3. TYPE OF WORK: New Well [X] Recondition [ ] Deepen [ ] Other [ ]

4. PROPOSED USE: Domestic [X] Irrigation [ ] Test [ ] Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL: Cable [ ] Rotary [X] Other [ ] air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Brown sand		3	9	6
Brown sandy clay		9	52	43
Brown clay		52	79	27
Soft zone, sandy		79	89	10
Brown sandy clay		89	110	21
Soft zone, sand NO H2O		110	115	5
Brown sandy clay, some DG		115	179	64
Soft zone, Med. sand	X	179	205	26
Granite		205	210	5

Date started 6-20-84, 19
Date completed 6-21-84, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10 x 6 inches Total depth 210 feet
Casing record 210
Weight per foot ..... Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	210 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type cement
Depth of seal 50 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 210 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 2½ x 6 around
From 182 feet to 202 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 135 feet below land surface
Flow 16 G.P.M. ..... P.S.I.
Water temperature cold °F. Quality clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number 14043
Nevada contractor's drillers number 908
Nevada driller's license number 923 (Actual Driller)
Signed [signature] (Contractor)
Date June 29, 1984

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434