WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 25533
Permit No. DOMESTIC
Basin TRUCKEE MEAD. 6-87

I

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3866

1. OWNER: BOB HOWELL
MAILING ADDRESS: 1825 Ben Franklin, Reno, NV 89509
ADDRESS AT WELL LOCATION: 7770 Kevin Cr., Reno, NV 895

2. LOCATION: NE ¼ NE ¼ Sec. 2 T. 18N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. Cottonwood Estates (Subdivision Name)

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐ air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Gravels, sand & some				
bigger boulders		1	21	20
Soft zone		21	22	1
Soft brown clays & gravels				
some sands		22	43	21
Brown sandy clay		43	64	21
Cemented gravels & sand		64	70	6
Soft zone	x	70	73	3
Gravels & sand cemented				
with brown clay		73	115	42
Soft zone, med. sand	x	115	117	2
Gravels & sand cemented				
with brown sandy clay		117	123	6
Soft zone - sand	x	123	129	6
Gravels & sand cemented				
with brown clay		129	143	14
Brown clay		143	148	5
Brown volcanic rock		148	150	2

Date started 7-3-84, 19
Date completed 7-9-84, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 10 x 6 inches Total depth 150 feet
Casing record 150
Weight per foot ____ Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 55 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 55 feet to 150 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 2¼ x 6 around
From 81 feet to 141 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 25 feet below land surface
Flow 20 G.P.M. ____ P.S.I.
Water temperature cold °F. Quality clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number 14043
Nevada contractor's drillers number 908
Nevada driller's license number 923 (Actual Driller)
Signed [signature] (Contractor)
Date July 11, 1984

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434