



WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 143B

PRINT OR TYPE ONLY

1. OWNER Pat Meader ADDRESS AT WELL LOCATION None N 95A
 MAILING ADDRESS 9 Palomino #17
Yerington NV

2. LOCATION SW 1/4 SW 1/4 Sec. 3 T. 14 N/S R. 25 E LYON County

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy loam topsoil		0	12	12
Fine sand & pea gravel	X	12	60	48
Blue Sandy Clay		60	68	8
Brown Sandy Clay		68	77	9
Sand & Gravel		77	110	33
Brown Sandy Clay		110	112	2

8. WELL CONSTRUCTION
 Diameter hole 6 inches Total depth 110 feet
 Casing record 0-112
 Weight per foot _____ Thickness 280

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>112</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Cement
 Depth of seal 0-50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation Saw Slot
 Size perforation 2 1/2 x 3/32
 From 97 feet to 107 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 18 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold ° F. Quality Good

Date started August 21, 1984
 Date completed August 23, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Edmund Miller Contractor
 Address Box 92 Smith, NV 89430 Contractor
 Nevada contractor's license number 12272
 Nevada contractor's drillers number 718
 Nevada driller's license number 1226 Actual Driller
 Signed Mitch Miller Contractor
 Date 8-23-84

BAILER TEST
 G.P.M. 20 Draw down 0 feet 1/2 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours