WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

FILED LATE

OFFICE USE ONLY
Log No. 25694
Permit No. DOMESTIC
Basin CARSON V. 08-105

1. OWNER Roger Bitton ADDRESS 776 Roan Circle
PO Box 1525 Gardnerville Nev 89410 Gardnerville Nev

2. LOCATION NE ¼ NE ¼ Sec. 24 T. 12 N/S R. 20 E. Douglas County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay Rock		0	80	80
Fractured Rock		80	120	40
Gravel + Water		120	140	20

Date started 6/18, 19 84
Date completed 6/20, 19 84

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blown	20	0	2 HRS

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10" inches Total depth 138 feet
Casing record 6 5/8
Weight per foot 10.89 Thickness .156

Diameter		From		To	
6 5/8	inches	0	feet	138	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 138 feet

Perforations:
Type perforation Factory
Size perforation 3/32 x 3 Double Slott
From 119 feet to 138 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 115 Feet below land surface
Flow 0 G.P.M. 20
Water temperature Cold ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sierra Pump + Drilling
Address Carson City
Nevada contractor's license number 0122360
Nevada driller's license number 1001
Signed J R Strauss
Date 6/20/84

USE ADDITIONAL SHEETS IF NECESSARY

O-627