

Log No. 25756  
 Permit No. 003-14-202  
 Basin Tracy



**WELL DRILLERS REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4614

1. OWNER Jeff Currier ADDRESS AT WELL LOCATION 1835 Lousetown  
 MAILING ADDRESS P. O. Box 330  
Virginia City, Nv 89440 Lot 35 Block 0 Unit 1  
 2. LOCATION NW  $\frac{1}{4}$  NW  $\frac{1}{4}$  Sec. 4 T. 17 N/S R. 21 E. Storey County  
 PERMIT NO. 003-14-202 Virginia City Highlands Subdivision Name  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Lite gray rock -soft</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>Brown clay &amp; soft rock</u>		<u>10</u>	<u>23</u>	<u>13</u>
<u>brown and black medium hard rock</u>		<u>23</u>	<u>30</u>	<u>7</u>
<u>brown clay and fractured rock</u>		<u>30</u>	<u>68</u>	<u>38</u>
<u>blue rock with white &amp; gray medium soft</u>		<u>68</u>	<u>92</u>	<u>24</u>
<u>Blue &amp; rock mixed with altered volcanic -yellow and brown</u>		<u>92</u>	<u>139</u>	<u>47</u>
<u>Hard fractured black rock</u>		<u>139</u>	<u>141</u>	<u>2</u>
<u>T.D. 141</u>				

8. 10" for 60' WELL CONSTRUCTION  
 Diameter hole 8 inches Total depth 141 feet  
 Casing record 6 5/8  
 Weight per foot 10.78 Thickness .156  
 Diameter 6 5/8 inches From +18" feet To 141 feet  
 Surface seal: Yes  No  Type grout  
 Depth of seal 55 feet  
 Gravel packed: Yes  No   
 Gravel packed from 55 feet to 141 feet  
 Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 121 feet to 141 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 9/20 1984  
 Date completed 9/20 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blew well with air to clean and develop.</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL  
 Static water level 90' feet below land surface  
 Flow 25 G.P.M. P.S.I.  
 Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name 2171 Aqua Drilling and Well Service, Inc. Contractor  
 Address 2255 Glendale Ave. Sparks, Nv 89431 Contractor  
 Nevada contractor's license number 15291  
 Nevada contractor's drillers number 1132  
 Nevada driller's license number 1132 Actual Driller  
 Signed Roger M. Thrall Contractor  
 Date Sept. 24, 1984