



WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3189

1. OWNER RALPH HALL ADDRESS AT WELL LOCATION SAME
 MAILING ADDRESS 75 Hwy 95A
YERRINGTON NEV 89447
 2. LOCATION SE 1/4 SW 1/4 Sec. 11 T. 13 N. R. 35 E. LYON County
 PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND-CLAY		0	10	10
SAND WATER	10	10	20	10
SAND-GRAVEL				
WATER	20	20	75	55
CLAY		75	80	5
SAND GRAVEL				
WATER	80	80	115	35

8. WELL CONSTRUCTION
 Diameter hole 8 inches Total depth 115 feet
 Casing record BLANK TO 85'
 Weight per foot Thickness 1.89
 Diameter From To
12 inches 0 feet 50 feet
8 inches 50 feet 115 feet
 Surface seal: Yes No Type CEMENT
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation MACHINE
 Size perforation 3/32
 From 85 feet to 115 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 10 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality Good

Date started 8-27, 1984
 Date completed 9-8, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>1 HP</u>	<u>30</u>	<u>3</u>	<u>12</u>

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ACE PUMP SALES SER Contractor
 Address 5551 Hwy 50 EAST MASON CITY Contractor
 Nevada contractor's license number 15489
 Nevada contractor's drillers number 203
 Nevada driller's license number 561 Actual Driller
 Signed James W Thompson Contractor
 Date 10-1-84

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours