



**WELL DRILLERS REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4610

1. OWNER Robert Dinsmore ADDRESS AT WELL LOCATION 1909 Sorrel  
 MAILING ADDRESS P. O. Box 218  
Minden, Nv 89423

2. LOCATION SW  $\frac{1}{4}$  NE  $\frac{1}{4}$  Sec. 24 T. 12 N/S R. 20 E Douglas County  
 PERMIT NO. 29 X 452 03 Ruhenstroth's Ranches  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay and sands fine to coarse		0	98	98
cobbles with brown clay		98	105	7
Brown clay and sand		105	117	12
cobbles cemented with very little clay		117	221	104
T. D. 221				

8. 10" T.D. WELL CONSTRUCTION  
 Diameter hole 10" inches Total depth 221 feet  
 Casing record 6 5/8 .156 to .250  
 Weight per foot 10.78 Thickness 156 to .250

Diameter	From	To
<u>6 5/8</u> inches	<u>+2</u> feet	<u>221</u> feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes  No  Type grout  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 221 feet

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3 - double  
 From 157 feet to 221 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 120 feet below land surface  
 Flow 25+ G.P.M. P.S.I.  
 Water temperature cool ° F. Quality good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling and Well Service, Inc.  
Contractor  
 Address 2255 Glendale Sparks, Nv 89431  
Contractor  
 Nevada contractor's license number 15291  
 Nevada contractor's drillers number 1132  
 Nevada driller's license number 1132  
Actual Driller  
 Signed Roger M. Thrall Contractor  
 Date 10/2/84

Date started 9/30 1984  
 Date completed 10/2 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blew well for 1 hour to clean and develop</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours