



WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 42451

PRINT OR TYPE ONLY

1. OWNER H. S. Wilcox ADDRESS AT WELL LOCATION 4207 Kyle Rd. Topaz states
Sishop, Calif. 95514 Bosler subdivision
 2. LOCATION 1/4 Sec. 14 T. 10 N/S R. 22 E. Douglas County Douglas
 PERMIT NO. 77-147-22 Bosler subdivision
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay & Boulder		0	28	
Blue Clay & Boulder		28	59	
Brown Clay & Boulder		59	96	
Redden, Clay		96	140	
		90		

8. WELL CONSTRUCTION
 Diameter hole 8 inches Total depth 140 feet
 Casing record 8 5/8 188
 Weight per foot 16.9 Thickness 188

Diameter	From	To
<u>12</u> inches	<u>0</u> feet	<u>150</u> feet
<u>8</u> inches	<u>50</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Factory
 Size perforation 1/8
 From 120 feet to 140 feet
 From _____ feet to _____ feet

Date started 8-17, 1984
 Date completed 10-9, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 90 feet below land surface
 Flow no G.P.M. P.S.I.
 Water temperature CO.L.D. Quality Unknown

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Dierra Pump & Drilling Co. Contractor
 Address 4639 Hwy. 50 E. Carson City, ev
 Nevada contractor's license number 0122768
 Nevada contractor's drillers number 1393
 Nevada driller's license number 1394
 Signed Curtis Blodswell Actual Driller
 Contractor
 Date 10-11-84

BAILER TEST
 G.P.M. 15 Draw down 30 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours