

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 4524

1. OWNER Maria Bennett ADDRESS AT WELL LOCATION Ryan Lane
 MAILING ADDRESS Box 932
Elko Nevada

2. LOCATION SW 1/4 SW 1/4 Sec. 31 T. 36 N/S R. 57 E Elko County _____
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other win

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silt</u>		<u>0</u>	<u>3</u>	
<u>Sandy clay</u>		<u>3</u>	<u>33</u>	
<u>Sandstone</u>		<u>33</u>	<u>57</u>	
<u>cemented gravel</u>	<u>X</u>	<u>57</u>	<u>84</u>	
<u>silt clay</u>		<u>84</u>	<u>87</u>	
<u>cemented gravel</u>	<u>X</u>	<u>87</u>	<u>100</u>	

8. WELL CONSTRUCTION

Diameter hole 12 inches Total depth 101 feet
 Casing record _____
 Weight per foot _____ Thickness 156 / 188

Diameter	From	To
<u>6</u> inches	<u>11</u> feet	<u>100</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement gravel
 Depth of seal 70 feet
 Gravel packed: Yes No
 Gravel packed from 70 feet to 100 feet

Perforations:
 Type perforation Factory drilled
 Size perforation 1/2" x 3/16"
 From 80 feet to 100 feet
 From _____ feet to _____ feet

Date started 8/5/85
 Date completed 8/7/85

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL

Static water level 74 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature cool ° F. Quality good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name R.D. Reynolds Drilling Contractor
 Address Wells, Nevada Contractor
 Nevada contractor's license number 014410
 Nevada contractor's drillers number 1390
 Nevada driller's license number 1390 Actual Driller
 Signed [Signature] Contractor
 Date 8/10/85

BAHER TEST

G.P.M. 20 Draw down 20 feet 2 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours