WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 25922
Permit No.
Basin 4-66 Kelley Creek Area

NOTICE OF INTENT NO. 5576

1. OWNER PINSON MINING COMPANY
MAILING ADDRESS P. O. BOX 192
WINNEMUCCA, NV 89445

ADDRESS AT WELL LOCATION
ADJACENT TO WATER WELLS 37949 & 37950
KELLEY CREEK BASIN - EAST SIDE OSGOOD MTS

2. LOCATION NE ¼ NE ¼ Sec. 33 T. 38 (N)/S R. 42 E HUMBOLT County
PERMIT NO. W- 5-16-85 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE (2A) Monitor
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Reverse

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay & cobbles		0	66	66
Cobbles, cemented gravel & clay lenses		66	242	176
gravel & clay mixed		242	274	32
gravel w/layered rock		274	332	58
gravel w/layered rock mixed w/some clay	XX	332	353	21
clay mixed w/some gravel	XX	353	372	19
clay w/little gravel	XX	372	380	8
rock - limestone	XX	380	500	120

Date started June 8, 19 85
Date completed June 11, 19 85

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 500 feet
Casing record 3 inch schedule 40 PVC
Weight per foot ..... Thickness .....

Diameter	From	To
3 inches	+2 feet	500 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement grout
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐ well rock local
Gravel packed from 50 feet to 500 feet

Perforations:
Type perforation SAW CUT
Size perforation 2-1/2" x 1/8"
From 140 feet to 500 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 291 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CHARLES SARGENT IRRIGATION, INC. (Contractor)
Address P. O. BOX 2480 RENO, NV 89505 (Contractor)
Nevada contractor's license number 21246
Nevada contractor's drillers number 1392
Nevada driller's license number 1388 (Actual Driller)
Signed [signature] (Contractor)
Date JULY 22, 1985

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434