WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 25951
Permit No. 48998
Basin IMLAY AREA - 72

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6391

1. OWNER PEGASUS GOLD CORP.
MAILING ADDRESS 1143 WEST FOURTH STREET
WINNEMUCCA, NEVADA 89445

ADDRESS AT WELL LOCATION
SOUTH OF EXIT 138 - HIGHWAY 80

2. LOCATION ~~NW~~ SE ¼ NW ¼ Sec. 3 T. 31 (N) S R. 33 E PERSHING County
PERMIT NO. 48998 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PW# 1 PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
large cobbles with mixed clay & gravel		0	60	60
gravel & clay mixed		60	105	45
clay & gravel stringers	XX	105	575	470
fractured volcanic rock	XX	575	587	12

Date started MARCH 5, 1986
Date completed APRIL 28 (PUMP), 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1100	200	120	24

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 17½ inches Total depth 580 feet
Casing record 12-3/4 inch O.D. x .250 inch wall
Weight per foot 33.38 Thickness

Diameter	From	To
conductor inches	feet	feet
26 - 20 inches	+2 feet	60 feet
inches	feet	feet
17½ - 12-3/4 inches	+2 feet	580 feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement grout
Depth of seal 60 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from +2 feet to 580 feet
1/8" to 1/4" quartz pebbles
Perforations:
Type perforation 12" JOHNSON HI-CAP WELL SCREEN
Size perforation .80 slot
From 150 feet to 250 feet
From 270 feet to 570 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 120 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 212 °F. Quality mineralized

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CHARLES SARGENT IRRIGATION, INC. (Contractor)
Address 9955 NORTH VIRGINIA STREET RENO, NV 89506 (Contractor)
Nevada contractor's license number 21246
Nevada contractor's drillers number 1392
Nevada driller's license number 1388 (Actual Driller)
Signed Steve Magill (Contractor)
Date APRIL 28, 1986

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434