WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 25967
Permit No.
Basin 6-85 Spanish Springs V.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4747

1. OWNER Mike Robins
MAILING ADDRESS

ADDRESS AT WELL LOCATION Spanish Springs Valley Ranches
No address as of yet

2. LOCATION SW ¼ SE ¼ Sec. 8 T. 21 N S R. 24 E Washoe County

County PERMIT NO. 2550 (Issued by Water Resources) | 76-300-30 (Parcel No.) | 21E (Subdivision Name)

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
soft DG		0	17	17
Brown sandy clay		17	25	8
Light Brown DG		25	29	4
Grey Hard Granite		29	35	6
Hard Green Granite		35	264	129
Hard Grey Granite		264	280	16
Red hard rock		280	282	2
Hard Green Granite		282	310	28
Hard Black Granite		310	383	73
Brown Clay and DG		383	408	25
Hard Green + Black Granite		408	420	12
Hard Black + White Granite		420	445	25
Med Hard Black + White Granite	✓	445	562	117

Date started Oct 17, 1985
Date completed Oct 26, 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter hole 8½ inches Total depth 562 feet
Casing record
Weight per foot ..... Thickness .156

Diameter	From	To
6⅝ inches	0 feet	562 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement Grout
Depth of seal 150 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 150 feet to 562 feet

Perforations:
Type perforation Mill slot
Size perforation 1/8 x 2½
From 532 feet to 562 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL

Static water level 470 feet below land surface
~~Flow~~ Approx. 20 G.P.M. ~~P.S.I.~~
Water temperature cold ° F. Quality

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of ~~my~~ knowledge.

Name Paul Williams & Sons (Contractor)
Address 22 So. Patterson Pl. Sparks (Contractor)
Nevada contractor's license number ~~957~~ 14483
Nevada contractor's drillers number 957
Nevada driller's license number 1460 (Actual Driller)
Signed Paul E. Williams (Contractor)
Date Oct 29, 1985

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434