WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 25975
Permit No.
Basin 6-83 Tracy Segment

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6919

1. OWNER KEN & CAROL Mc CABE
MAILING ADDRESS 3710 Churchill Drive
Carson City, Nevada 89710

ADDRESS AT WELL LOCATION 2465 Cartwright

2. LOCATION NW ¼ NE ¼ Sec. 32 T. 18 N/S R. 21 E Storey County

PERMIT NO.		
Issued by Water Resources	03-023-11 Parcel No.	VCH Subdivision Name

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ] AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Decomposed Volcanic Rock		0	20	
Volcanic Rock - Brown		20	50	
Volcanic Rock with some clay's - Brown		50	60	
Volcanic Rock - green and black		60	70	
Blue Clay with Red Rock		70	100	
Gray Clay & Sandstone and green rock		100	140	
Black Rock		140	158	
T.D. 158				

Date started 6/5/ 19 85
Date completed 6/6/ 19 85

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well with air to clean and develop			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. 10" - 50' WELL CONSTRUCTION
Diameter hole 8" inches Total depth 158 feet
Casing record 6 5/8"
Weight per foot 10.78 Thickness .156

Diameter	From	To
6 5/8" inches	+2 feet	158 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type Grout
Depth of seal 50 ft. feet
Gravel packed: Yes XX No [ ]
Gravel packed from 50 feet to 158 feet

Perforations:
Type perforation Factory
Size perforation 3/32X3
From 138 feet to 158 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 70 ft feet below land surface
Flow 10-12 G.P.M. P.S.I.
Water temperature Cold ° F. Quality Clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua DRilling & Well Service Inc. Contractor
Address 2255 Glendale AVe. Sparks, Nevada 89431 Contractor
Nevada contractor's license number 15291
Nevada contractor's drillers number 1132
Nevada driller's license number 1439 Actual Driller
Signed Roger M Thrall Contractor
Roger M. Thrall
Date 6/6/85

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434