

**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 6181

PRINT OR TYPE ONLY

1. OWNER John Burroughs ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1601 Kuenzli St. 21390 Sarazac  
Reno, Nv 89502

2. LOCATION SW  $\frac{1}{4}$  SW  $\frac{1}{4}$  Sec. 32 T. 18 N/S R. 21 E Storey County \_\_\_\_\_  
 PERMIT NO. 03-052-28 - Lot 60 Block K Virginia City Highlands  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gray Clay		0	40	40
Yellow clay		40	95	55
Some rock layers with blue & green mixed with yellow clay		95	151	56
Blue & green rock mixed with white specs & quartz		151	196	45
H <sub>2</sub> O at 189				
T.D. 196				

8.10"-50" WELL CONSTRUCTION  
 Diameter hole 8 inches Total depth 196 feet  
 Casing record 6 5/8 inches  
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+2</u> feet	<u>196</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type grout  
 Depth of seal 30 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 196 feet

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 176 feet to 196 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 11/1/85, 19\_\_\_\_  
 Date completed 11/4/85, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL  
 Static water level 140 feet below land surface  
 Flow 20+ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling and Well Service, Inc. Contractor  
 Address 2255 Glendale Ave. Sparks, Nv 89431 Contractor  
 Nevada contractor's license number 15291  
 Nevada contractor's drillers number 1132  
 Nevada driller's license number 1132 Actual Driller  
 Signed Roger M. Thrall Contractor  
 Date 11/8/85