WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 25985
Permit No. 38766
Basin G-85 Tracy Segment

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4742

1. OWNER Story Co. Properties
MAILING ADDRESS 100 West Grove St
Reno, Nev Suite 550
ADDRESS AT WELL LOCATION Lockwood
Dump a well

2. LOCATION NW ¼ NW ¼ Sec. 22 T. 19 N/S R. 21 E. Washoe County
PERMIT NO. 38766 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☑

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☑
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
soft diamicrons		0	17	17
with light gray				
red volcanic rock		17	27	10
soft gray rock		27	43	16
soft gray vole. Rock		43	109	66
w/clay layers				
gray sandy clay		109	187	78
w/soft vole. rock				
gray clay (hard)		187	211	24
sandy clay thin		211	225	14
hard fractured		225	245	20
Volcanic Rock				
fine gravel & clay	X	245	255	10
hard layer vole. rock		255	257	2
Blue Vole. Rock soft	X	257	275	18
soft Blue shale &		275	385	110
clay layers				
Hard fractured vole.		385	390	5
soft shale & clay		390	495	5
layers.		~~495~~	~~551~~	
Red vole Rock (med)		495	551	56
Multi colored soft		551	766	15
Vole. Rock		~~766~~	~~775~~	
Multi colored Vole		766	775	8
Rock (Med hard)				

Date started 8-7, 1985
Date completed 8-12-, 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 1/4 inches Total depth 225 feet
Casing record 12 3/4 o.d. conductor
Weight per foot 33.38 Thickness .250

Diameter	From	To
inches	feet	feet
C inches	22 feet	feet
inches	feet	feet
To Be Removed	feet	feet
inches	feet	feet
to deepen & case hole	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☑ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation X
Size perforation
From feet to feet
From feet to feet
From X feet to X feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 223 feet below land surface
Flow approx. 15 G.P.M. ~~P.S.I.~~
Water temperature ° F. Quality unknown

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Paul Williams & Sons Drilling (Contractor)
Address 22 S. Pattison, Sparks Nev. (Contractor)
Nevada contractor's license number 14483
Nevada contractor's drillers number 957
Nevada driller's license number 957 (Actual Driller)
Signed Paul E. Williams Sr. (Contractor)
Date 8-14-85

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434