

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 6924

1. OWNER Wayne Dennis ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2591 Monte Verde 6755 Quaking Aspen
Sparks, Nv 89431 Palomino Valley
 2. LOCATION SW $\frac{1}{4}$ NE $\frac{1}{4}$ Sec. 4 T. 21 N/S R. 22 E Washoe County
 PERMIT NO. 77-250-06 Parcel No. _____ Subdivision Name _____
Issued by Water Resources

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay & multi colored rock		0	41	41
Hard smooth brown volcanic rock		41	52	9
red brown volcanic rock with brown clay		52	76	24
blue green clay stone with volcanic chips clear & smoke chips		76	155	79
brown & red sandstone with volcanic chips some green & clay		155	208	53
brown & tan rock with Purple & white specs First H2o at 285-305 tan & lite brown rock with clear & smoke chips		208	370	162
clay mix quartz smooth green specs-fine green sandstone with fine quartz & redish clay		370	375	5
		375	390	15
		390	465	75

8. 10"-50' WELL CONSTRUCTION
 Diameter hole 8 inches Total depth 291 feet
 Casing record 6 5/8"
 Weight per foot 10.52 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+3</u> feet	<u>291</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 291 feet
 Perforations:
 Type perforation factory
 Size perforation 3/32 X 3 .250
 From 271 feet to 291 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 100 feet below land surface
 Flow 6 G.P.M. P.S.I. _____
 Water temperature cool ° F. Quality milky

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling and Well Service, Inc. Contractor
 Address 2255 Glendale Ave. Sparks, Nv 89431 Contractor
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1132 Actual Driller
 Signed Roger M. Thrall Contractor
 Date 5/9/86

Date started 4/25/86, 19____
 Date completed 4/29/86, 19____
 **NOTE There is a 1 1/2 HP pump and 189ft of 1" T/C 7 gal. pipe and a WELL TEST DATA 6 5/8" OD fishing tool in the bottom of this well.

Pump RPM	G.P.M.	Draw Down	After Hours Pump
The drill rig was used to push the 1" and the fishing tool down below the water strata.			
Blew well for 2 hrs. & 15 min to clean and develop.			

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours