

**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 5517

PRINT OR TYPE ONLY

1. OWNER Lonnie Burns ADDRESS AT WELL LOCATION 445 Anniversary Rd Palomino Valley  
 MAILING ADDRESS P. O. Box 2001 Sparks, NV 89431 - 2001

2. LOCATION NW  $\frac{1}{4}$  NW  $\frac{1}{4}$  Sec. X 11 T. 22 N/S R. 20 E Washoe County  
 PERMIT NO. 76-130-02 - Palomino V. Unit 3 11-2-8-1  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
D. G.		0	100	100
Semi D.G. with quartz and pyrite		100	185	85
Hard granite with frequent fractures		185	246	61
T.D. 240				

8. 10" for 60' WELL CONSTRUCTION  
 Diameter hole 8 inches Total depth 240 feet  
 Casing record 6"  
 Weight per foot 10.78 Thickness .156  
 Diameter 6 5/8 inches From 240 feet To \_\_\_\_\_ feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type grout  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 240 feet

Perforations:  
 Type perforation Factory .250 wall  
 Size perforation 3/32 X 3  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 220 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 3/6, 1985  
 Date completed 3/7, 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			
Pumped with pump	25 GPM+	pumping level	
105'			

9. WATER LEVEL  
 Static water level 95 feet below land surface  
 Flow 30+ G.P.M. P.S.I. \_\_\_\_\_  
 Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling and Well Service, Inc.  
 Contractor  
 Address 2255 Glendale Ave. Sparks, Nv 89431  
 Contractor  
 Nevada contractor's license number 15291  
 Nevada contractor's drillers number 1132  
 Nevada driller's license number 1039  
 Actual Driller  
 Signed Roger M. Thrall  
 Roger M. Thrall Contractor  
 Date 3/18/85

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours