

OFFICE USE ONLY
 Log No. 26000
 Permit No. _____
 Basin 6-84 Warm Springs V.

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 5527

PRINT OR TYPE ONLY

1. OWNER Stephen Wood
 MAILING ADDRESS 7595 Robert Banks Sparks, Nv 89431
 ADDRESS AT WELL LOCATION 6000 Winnemucca Ranch Road

2. LOCATION SW $\frac{1}{4}$ ne $\frac{1}{4}$ Sec. 12 11 T. 22 N/S R. 20 E Washoe County
 PERMIT NO. 76-130-2935 Parcel No. _____ Subdivision Name Palomino Valley unit 3 11-2-83
 Issued by Water Resources _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top sands		0	2	2
light colored D.G. with brown clay stringers		2	194	192
Multi-colored D.G. with gray clay stringers-occasional stringers of fine light sands	X	194	262	68
T. D. 262				

8. WELL CONSTRUCTION
 Diameter hole 10 inches Total depth 262 feet
 Casing record 6 5/8 - .156 & .250
 Weight per foot 10.78 - 17.02 Thickness .156 & .250
 Diameter 6 5/8 inches From + 2 feet To 262 feet
 Surface seal: Yes No Type grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 262 feet
 Perforations:
 Type perforation factory and perforator
 Size perforation 3/32 X 3 and 1/8" holes
 From 200 feet to 242 perforator feet
 From 242 feet to 262 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 59 feet below land surface
 Flow 10 -12 G.P.M. _____ P.S.I.
 Water temperature cool ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling and Well Service, Inc.
 Contractor
 Address 2255 Glendale Ave. Sparks, Nv 89431
 Contractor
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1039
 Actual Driller

Date started 2/27/85, 19____
 Date completed 3/4/85, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air for 1 hour and 50 minutes to clean and develop.			

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

Signed Roger M. Thrall
 Roger M. Thrall Contractor
 Date 3/6/85