

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 6732

1. OWNER Tom and Betty Donahue ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 7200 N. Virginia #199 _____
Reno, Nv 89506 _____
 2. LOCATION SE 1/4 SE 1/4 Sec 33 T. 23 N/S R. 21 E _____
Washoe County
 PERMIT NO. 077-350-01 _____
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Red to Red Gray volcanic rock		0	78	78
Gray & white volcanic rock		78	85	7
Hard fractured rock purple		85	86	1
Purple volcanic rock with white specs.		86	115	29
Redish volcanic rock with soft layers		115	150	35
Greenish gray volcanic rock		150	195	45
Green rock with some blue and white	X	195	217	22
T. D. 217				

8. 10"-50' WELL CONSTRUCTION
 Diameter hole 8 inches Total depth 217 feet
 Casing record 6 5/8
 Weight per foot 10.78 Thickness .156
 Diameter 6 5/8 inches +2 From 217 To _____ feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 217 feet

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 197 feet to 217 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 100 feet below land surface
 Flow 20+ G.P.M. _____ P.S.I.
 Water temperature cool F. Quality good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling and Well Service, Inc.
 Contractor
 Address 2255 Glendale Ave. Sparks, Nv 89431
 Contractor
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1132
 Actual Driller
 Signed Roger M. Thrall
 Roger M. Thrall Contractor
 Date 9/9/85

Date started 9/9/85, 19____
 Date completed 9/9/85, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Blew with air to clean and develop.

BAILER TEST

G.P.M.	Draw down	feet	hours