

OFFICE USE ONLY
 Log No. 26019
 Permit No. 43632, 48089
 Basin 6-85 Spanish Springs
 4618

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. _____

1. OWNER David N. Freer ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 470 Rockwell Blvd Spring Creek Subdivision
Sparks, Nv 89510
 2. LOCATION NE $\frac{1}{4}$ NE $\frac{1}{4}$ Sec. 21 T. 20 N/S R. 20 E. Washoe County
 PERMIT NO. 43632 83-291-13 _____
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay brown		0	28	28
Volcanic rock & clay		28	82	54
blue clay & volcanic sands		82	96	14
volcanic gravels	X	96	122	26
volcanic gravels & sand		122	161	39
volcanic rock -gray and red		161	190	29
brown and black rock		190	210	20
greenish blue rock soft (quartz & silver)	X	210	220	10
T. D. 220				

8. 12" for 60" WELL CONSTRUCTION
 Diameter hole 10" inches Total depth 220 feet
 Casing record 8 5/8 & 6 5/8
 Weight per foot 10.78 & 16.94 Thickness .156 & .188

Diameter	From	To
<u>8 5/8</u> inches	<u>3+</u> feet	<u>120</u> feet
<u>6 5/8</u> inches	<u>110</u> feet	<u>220</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type slurry
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 120 feet

Perforations:
 Type perforation factory single & double
 Size perforation 3/32 X 3
 From 100 feet to 120 feet
 From 178 feet to 220 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 10/15, 1984
 Date completed 10/16, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well with <input checked="" type="checkbox"/> air to clean and develop			

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL
 Static water level 22 feet below land surface
 Flow 150+ G.P.M. P.S.I. _____
 Water temperature cold ° F. Quality clear

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling and Well Service, Inc.
Contractor
 Address 2255 Glendale Ave. Sparks, Nv 89431
Contractor
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1132
Actual Driller
 Signed Roger M. Thrall
Roger M. Thrall Contractor
 Date 10/17/84