

**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 5802

PRINT OR TYPE ONLY

1. OWNER CLAUDIA & DOROTHY WOLFF ADDRESS AT WELL LOCATION Alamosa  
MAILING ADDRESS P.O. Box 7159 Reno, NV  
Santa Rosa, CA 95407

2. LOCATION SE 1/4 SW 1/4 Sec. 12 T. 21N N/S R. 20 E Washoe County  
PERMIT NO. \_\_\_\_\_ Spanish Springs  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other

4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock

5. TYPE WELL  
Cable  Rotary   
Other  air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown sand		0	19	19
Brown clay with DG		19	79	60
Soft Zone NO WATER		79	81	2
Brown clay with DG		81	139	58
Soft Zone NO WATER		139	141	2
Brown clay with DG		141	169	28
Weathered granite		169	220	51
Soft zone (5-6 GPM)	x	220	230	10
Weathered granite		230	271	41
Fracture small NO H2O		271	272	1
Weathered granite		272	294	22
Fracture small NO H2O		294	295	1
Weathered granite		295	351	56
Fracture (2-6 GPM)	x	351	355	4
Weathered granite		355	368	13
Fracture (5-6 GPM)	x	368	369	1
Weathered granite with yellow clay streaks		369	380	11
Fracture (10 GPM)	x	380	384	4
Weathered granite		384	400	6

8. WELL CONSTRUCTION  
Diameter hole 10 x 6 inches Total depth 400 feet  
Casing record 400  
Weight per foot \_\_\_\_\_ Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>400</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type cement  
Depth of seal 54 feet  
Gravel packed: Yes  No   
Gravel packed from 54 feet to 400 feet

Perforations:  
Type perforation factory sawed slot  
Size perforation 3/32 x 2 1/2 x 6 around

From	To
<u>216</u> feet	<u>226</u> feet
<u>343</u> feet	<u>353</u> feet
<u>375</u> feet	<u>395</u> feet
_____ feet	_____ feet
_____ feet	_____ feet

Date started 3-19-85, 19\_\_\_\_\_  
Date completed 3-21-85, 19\_\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL  
Static water level 146 feet below land surface  
Flow 25 G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F. Quality clear

10. DRILLERS CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Wayne Drilling of Nevada, Inc.  
Contractor  
Address P.O. Box 12370, Reno, NV 89510  
Contractor  
Nevada contractor's license number 22549  
Nevada contractor's drillers number 908  
Nevada driller's license number 923  
Actual Driller  
Signed Wayne C. Helman Contractor  
Date March 28, 1985

BAILER TEST

G.P.M.	Draw down	feet	hours