WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 26026
Permit No.
Basin 6-85 Spanish Springs V.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5652

1. OWNER Jim Monahan
MAILING ADDRESS 81 East Sheridan Way
Sparks, Nv 89431

ADDRESS AT WELL LOCATION 399 Calle Limpo
Spanish Springs

2. LOCATION SE ¼ Se ¼ Sec. 25 T. 21 N/S R. 20 E Washoe County
PERMIT NO. ____ Issued by Water Resources | 76-400-57 Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ] Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
D. G.		0	6	6
Multi-colored volcanic rock mixed with brown clay		6	160	154
Brown clay		160	180	20
Brown clay with white rock		180	200	20
Fine sand & white rock	X	200	262	2
T. D. 262				

Date started 4/22/85, 19
Date completed 4/23/85, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air for 4 hours to clean and develop.			

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. 10"- 55' WELL CONSTRUCTION
Diameter hole 8 inches Total depth 251 feet
Casing record 6"
Weight per foot 10.78 17.02 Thickness .156 & .250

Diameter	From	To
6 5/8 inches	+ 2' feet	251 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type grout
Depth of seal 50 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 251 feet

Perforations:
Type perforation factory
Size perforation 3/32 X 3 .250
From 231 feet to 251 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 156 feet below land surface
Flow 16 G.P.M. ____ P.S.I.
Water temperature cool °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling and Well Service, Inc. (Contractor)
Address 2255 Glendale Ave. Sparks, Nv 89431 (Contractor)
Nevada contractor's license number 15291
Nevada contractor's drillers number 1132
Nevada driller's license number 1439 (Actual Driller)
Signed Roger M. Thrall (Contractor)
Roger M. Thrall
Date 4/24/85

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434