

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 5823

PRINT OR TYPE ONLY

1. OWNER ED. AWEKA, SR. ADDRESS AT WELL LOCATION 565 Calle Bonito Crt
P.O. Box 2758 Sparks, NV 89431
 MAILING ADDRESS Sparks, NV 89431
 2. LOCATION NE 1/4 NE 1/4 Sec. 21 T. 21 N. N/S R. 21 E Washoe County
 PERMIT NO. 076-371-27-372-01 Spanish Springs
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other air

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--|--------------|------|-----|------------|
| Loose brown granite sands | | 0 | 3 | 3 |
| Weathered granite | | 3 | 33 | 30 |
| Soft zone | | 33 | 35 | 2 |
| Weathered granite | | 35 | 123 | 88 |
| Soft zone | | 123 | 128 | 5 |
| Weathered granite | | 128 | 210 | 82 |
| Fracture (NO WATER) | | 210 | 212 | 2 |
| Gray granite | | 212 | 339 | 127 |
| Fracture (NO WATER) | | 339 | 340 | 1 |
| Weathered soft granite | | 340 | 361 | 21 |
| Gray granite | | 361 | 397 | 36 |
| Big fracture (NO WATER) | | 397 | 401 | 4 |
| Gray granite | | 401 | 456 | 55 |
| Soft weathered granite | | 456 | 479 | 23 |
| Weathered granite | | 479 | 510 | 31 |
| Soft zone (NO WATER) | | 510 | 515 | 5 |
| Gray granite | | 515 | 595 | 80 |
| Soft zone (2-3GPM) | x | 595 | 599 | 4 |
| Gray granite | | 599 | 624 | 25 |
| Fractured granite with yellow clay streaks | x | 624 | 645 | 21 |
| Gray granite | | 645 | 655 | 10 |
| Fracture | x | 655 | 656 | 1 |
| Gray granite | | 656 | 665 | 9 |

8. WELL CONSTRUCTION
 Diameter hole 10 x 6 inches Total depth 665 feet
 Casing record 665
 Weight per foot _____ Thickness .156
 Diameter 6 5/8 inches From 0 feet To 665 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type cement
 Depth of seal 53 feet
 Gravel packed: Yes No
 Gravel packed from 53 feet to 665 feet
 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 2 1/2 x 6 around
 From 595 feet to 655 feet
 From _____ feet to _____ feet

Date started 8-14-85, 19_____
 Date completed 8-19-85, 19_____

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |

9. WATER LEVEL
 Static water level 420 feet below land surface
 Flow 20 G.P.M. _____ P.S.I.
 Water temperature cold F. Quality clear

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling of Nevada, Inc.
 Contractor
 Address P.O. Box 12370, Reno, NV 89510
 Contractor
 Nevada contractor's license number 22549
 Nevada contractor's drillers number 908
 Nevada driller's license number 923
 Actual Driller

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

Signed Wayne C. Hedman
 Contractor
 Date August 21, 1985