

OFFICE USE ONLY
 Log No. 26030
 Permit No. _____
 Basin G-25 Spanish Springs

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. _____

OWNER VINCENT L. CANCELLA ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 4698 Englewood Drive Calle De La Plata
San Jose, CA 95129 Sparks, NV 89431
 2. LOCATION 1/4 NW 1/4 NE NW 1/4 Sec. 2019 T 21 N/S R. 21 E Washoe County
 PERMIT NO. 76-371-24 Spanish Springs
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	2	2
Soft brown sands		2	7	5
Brown sandy clay		7	195	188
Soft zone	x	195	198	3
Brown sandy clay		198	228	30
Soft zone	x	228	233	5
Brown sandy clay		233	256	23
Gray clay		256	307	51
Weathered granite		307	380	73
Soft weathered granite				
with white clay streaks		380	403	23
Gray granite		403	431	28
Soft weathered granite				
with white clay streaks		431	440	9
Medium soft gray granite		440	450	10
TEST HOLE - BACK FILLED TO 450 FT.				
Medium soft gray granite		450	485	35
Black medium hard granite		485	523	38
Soft gray granite		523	561	38
Medium hard granite		561	579	18
Soft zone (NO WATER)		579	581	2
Gray granite, med. soft		581	593	12
Soft zone (NO WATER)		593	598	5
Gray granite, med. soft		598	630	32
Soft zone (NO WATER)		630	638	8
Gray granite, Med. hard		638	655	17

8. WELL CONSTRUCTION
 Diameter hole 10 x 6 inches Total depth 450 feet
 Casing record _____ Thickness .156
 Weight per foot _____
 Diameter From To
6 5/8 inches 0 feet 450 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type cement
 Depth of seal _____ 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ 50 feet to _____ 450 feet
 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 2 1/2 x 6 around
 From 200 feet to 220 feet
 From 380 feet to 440 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 8-19-85, 19_____
 Date completed 8-27-85, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 155 feet below land surface
 Flow 5 G.P.M. _____ P.S.I.
 Water temperature cold °F. Quality clear

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling of Nevada, Inc. Contractor
 Address P.O. Box 12370, Reno, NV 89510 Contractor
 Nevada contractor's license number 22549
 Nevada contractor's drillers number 908
 Nevada driller's license number 923 Actual Driller

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

Signed Wayne C. Adelman Contractor
 Date August 29, 1985