WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 26047
Permit No.
Basin G-87 Truckee

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6183

1. OWNER Daniel Ellis
MAILING ADDRESS P.O.Box 826
Virginia City, Nv 89440

ADDRESS AT WELL LOCATION
Vermillion Court Lot 23

2. LOCATION SW ¼ SW ¼ Sec. 6 T. 17 N/S R. 21 E. Storey County
PERMIT NO. — (Issued by Water Resources) | 03-442-08 (Parcel No.) | Merek Development (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Red brown clay and volcanic rock		0	14	14
Blue green clay		14	28	14
Yellowish clay and rock chips - white and tanish		28	166	138
Purple rock with white and brown specs some tanish with white specs		166	185	19
-Lost circulation - very hard rock layer				
gray clay & soft rock		185	570	385
gray & white rock medium		570	620	50
more white & than gray rock	X	620	760	140
T.D. 760				

Date started 1/9/86, 19
Date completed 1/15/86, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8" inches Total depth 748 feet
Casing record 6 5/8 .188
Weight per foot 12.92 Thickness .188

Diameter	From	To
6 5/8 inches	+2 feet	748 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type grout
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☐
Gravel packed from 50 feet to 748 feet

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 728 feet to 748 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level approx. 400' feet below land surface
Flow 15 G.P.M. P.S.I.
Water temperature cool °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling and Well Service, Inc. (Contractor)
Address 2255 Glendale Ave. Sparks Nv 89431 (Contractor)
Nevada contractor's license number 15291
Nevada contractor's drillers number 1132
Nevada driller's license number 1132 (Actual Driller)
Signed Roger M Thrall (Contractor)
Roger M. Thrall
Date 1/16/86

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434