

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. _____

OWNER Karen Gladding ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P. O. Box 552 Dry Gulch Rd - Lot 504
Virginia City, Nv 89440
 2. LOCATION SE $\frac{1}{4}$ SW $\frac{1}{4}$ Sec. 8 T. 17 N/S R. 21 E. Storey County
 PERMIT NO. 03-412-09 Highland Ranches
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown & gray clay		0	41	41
Gray clay & volcanic rock gray in color		41	89	48
Gray, green & blue rock - medium hard		89	147	58
Hard rock layer		147	151	4
Blue & green rock mixed with gray & white		151	214	63
yellow conglumerants of rock	X	214	218	4
T.D. 218				

8. 10"-50' WELL CONSTRUCTION
 Diameter hole 8 inches Total depth 218 feet
 Casing record 6 5/8
 Weight per foot 10.78 Thickness .156
 Diameter 6 5/8 inches From +2 feet To 218 feet
 Surface seal: Yes No Type grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 218 feet
 Perforations:
 Type perforation Factory
 Size perforation 3/32 X 3
 From 198 feet to 218 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 141 feet below land surface
 Flow 50+ G.P.M. P.S.I.
 Water temperature cool °F. Quality good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling and Well Service, Inc.
 Contractor
 Address 2255 Glendale Ave. Sparks, Nv 89431
 Contractor
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1132
 Actual Driller

Date started 11/6/85, 19____
 Date completed 11/7/85, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

Signed R M Thrall
Roger M. Thrall Contractor
 Date 11/8/85