WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 260059
Permit No.
Basin 87

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5809

1. OWNER KENNETH C. CUMMINGS
MAILING ADDRESS 440 Marsh Ave.
Reno, NV 89509

ADDRESS AT WELL LOCATION 2375 Kenney Lane
Reno, NV

2. LOCATION SW ¼ NE ¼ Sec. 2 T 18N N/S R 19 E Washoe County
PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Gray volcanic rock		3	10	7
Brown volcanic rock		10	61	51
Soft zone NO WATER		61	62	1
Brown volcanic rock		62	105	43
Soft zone NO WATER		105	106	1
Brown volcanic rock		106	156	50
Soft zone NO WATER		156	158	2
Gray volcanic rock		158	165	7
Fracture rock	X	165	171	6
Gray volcanic rock		171	179	8
Reddish brown volcanic rock		179	190	11
Fracture	X	190	194	4
Reddish brown volcanic rock		194	217	23
Red rock		217	223	6

Date started 4-12-85, 19____
Date completed 4-13-85, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 10 x 6 inches Total depth 223 feet
Casing record 223
Weight per foot ____ Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	223 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 51 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 51 feet to 223 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 2½ x 6 around
From 175 feet to 219 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 51 feet below land surface
Flow 14 G.P.M. ____ P.S.I.
Water temperature cold °F. Quality clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling of Nevada, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number 22549
Nevada contractor's drillers number 908
Nevada driller's license number 923 (Actual Driller)
Signed [signature] (Contractor)
Date April 16, 1985

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434