

T

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4753

1. OWNER Ian Mac Farlane ADDRESS AT WELL LOCATION 40 MacFarlane Dr
 MAILING ADDRESS 3825 Frost Dr. Reno Nev. Reno Nev.

2. LOCATION 1/4 NW Sec 2 T 18 N/S R 19 E Washoe County
 PERMIT NO. 47-290-03 Lone Tree Estates Parcel No. Subdivision Name

Issued by Water Resources

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy Clay</u>		<u>0</u>	<u>43</u>	<u>43</u>
<u>Decadid granite</u>		<u>43</u>	<u>101</u>	<u>58</u>
<u>Reddish gray</u> <u>Walc. rock</u> <u>(fractured)</u>		<u>101</u>	<u>133</u>	<u>32</u>
<u>Red Walc. Rock</u> <u>(fractured)</u>		<u>133</u>	<u>150</u>	<u>17</u>

8. WELL CONSTRUCTION

Diameter hole 10 inches Total depth 150 feet
 Casing record
 Weight per foot 19 Thickness 1.56
 Diameter 6.580 inches From 0 feet To 150 feet
 Surface seal: Yes No Type grout
 Depth of seal 60 feet
 Gravel packed: Yes No
 Gravel packed from 60 feet to 150 feet

Perforations:
 Type perforation factory sawed
 Size perforation 5-32 x 2 1/2"
 From 110 feet to 150 feet

9. WATER LEVEL

Static water level approx. 60ft feet below land surface
 Flow _____ G.P.M. approx. 25
 Water temperature 58 ° F. Quality unknown

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Paul Williams & Sons Contractor
 Address 22 So. Patterson, Sparks. Contractor
 Nevada contractor's license number 14483
 Nevada contractor's drillers number 957
 Nevada driller's license number 957
 Signed Paul Williams & Sons Contractor
 Date 3-20-86

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours