WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 26064
Permit No.
Basin 87.

I

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4754

1. OWNER Dennis Pickavance
MAILING ADDRESS 1140 Skyline Boul. Reno
ADDRESS AT WELL LOCATION 4050 Lone Tree lane Reno

2. LOCATION NE ¼ NE ¼ Sec. 11 T. 18 N/S R. 19 E. Washoe County
PERMIT NO. Co. (Issued by Water Resources) 41-130-06 (Parcel No.) Lone tree Estates (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy clay		0	17	17
sand & gravel		17	51	34
fine sand		51	94	43
sandy & gravel		94	128	34
Valve rock w/fractures	X	128	213	85

Date started 3-19, 1986
Date completed 3-21, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10 to 138 inches Total depth 213 feet
Casing record
Weight per foot 9 LB. Thickness .156

Diameter	From	To
6 5/8 od inches	0 feet	138 feet
inches	feet	feet
inches	feet	feet
5 9/16 od inches	113 feet	213 feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type grout
Depth of seal 59 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 59 feet to 138 feet

Perforations:
Type perforation factory sawed
Size perforation 3/32 x 2½
From ..... feet to ..... feet
From 6 5/8 118 feet to 138 feet
From ..... feet to ..... feet
From 5 9/16 177 feet to 213 feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level approx. 70 feet below land surface
G.P.M. approx 30
Water temperature 58 °F. Quality unknown

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Paul Williams & Sons (Contractor)
Address 22 So. Patterson, Sparks, Nev (Contractor)
Nevada contractor's license number 14483
Nevada contractor's drillers number 957
Nevada driller's license number 957 (Actual Driller)
Signed Paul E. Williams Sr. (Contractor)
Date 3-30-86

(Rev. 6-81)
USE ADDITIONAL SHEETS IF NECESSARY
O-627 CR434