

26065  
 OFFICE USE ONLY  
 Log No. 26065  
 Permit No.  
 Basin 6-87 Truckee Meadows

**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 6047

PRINT OR TYPE ONLY

1. OWNER Larry McNabney ADDRESS AT WELL LOCATION 8520 Bellhaven Rd  
 MAILING ADDRESS 36 Stewart St.  
Reno, Nv 89501

2. LOCATION NW X NE 1/4 Sec. 11 T. 18 N/S R. 19 E Washoe County  
 PERMIT NO. 041-130-29  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>cobbles and brown clay</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>brown clay</u>		<u>3</u>	<u>23</u>	<u>20</u>
<u>multi colored sands with some clay - lite brown</u>		<u>23</u>	<u>40</u>	<u>17</u>
<u>multi-colored sands with scattered cobbles and clay layers</u>		<u>40</u>	<u>377</u>	<u>337</u>
<u>volcanic rock reddish and black</u>		<u>377</u>	<u>410</u>	<u>33</u>
T.D. <u>410</u>				

8. 10"-60" WELL CONSTRUCTION

Diameter hole 8 1/2 inches Total depth 410 feet  
 Casing record 6 5/8 .188  
 Weight per foot 12.92 Thickness .188

Diameter	From	To
<u>6 5/8</u> inches	<u>+2</u> feet	<u>230</u> feet
<u>4 1/2</u> inches	<u>225</u> feet	<u>410</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type neat cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 410 feet

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 212 feet to 232 feet  
 From 390 feet to 410 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 4/17/86, 19\_\_\_\_  
 Date completed 4/21/86, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blew well with air to clean and develop.</u>			

9. WATER LEVEL  
 Static water level 95 feet below land surface  
 Flow 18+ G.P.M. P.S.I.  
 Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling and Well Service, INC.  
 Contractor  
 Address 2255 Glendale Ave. Sparks, Nv 89431  
 Contractor  
 Nevada contractor's license number 15291  
 Nevada contractor's drillers number 1132  
 Nevada driller's license number 1132  
 Actual Driller  
 Signed Roger M. Thrall  
 Roger M. Thrall Contractor  
 Date 4/21/86

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours